



# LINGJACK ENGINEERING WORKS PTE LTD

No.1 Woodlands Terrace, Lingjack Industrial Building, Singapore 738471

Tel : (65) 67594163 Fax : (65) 67587513 Web site: [www.combat.com.sg](http://www.combat.com.sg)

Co Reg No. : 199103053M GST Reg no. : M2-0100375-0

Data Sheet No.: 90803400

## 3Way Non Controllable Pillar Hydrant



Model	PH150
Description	3 Way Non Controllable Pillar Hydrant
Test Pressure	25kgf/cm <sup>2</sup> (360 PSI) @ 5min
Max. Working Pressure	16kgf/cm <sup>2</sup> (230 PSI)
Body Material	Cast Iron
Design	In Compliance with BS750: 1984
Flange Size	150mm PN16 (BS EN 1092-2:1997); Optional: 6"ANSI #150RF
Outlet	2 x 2 1/2"LVT Male Thread and Pumper Outlet size:4"
Acessories	Hydrant Adaptor 2 1/2" LVT to 2 1/2" Female instantaneous ( BS 336 )

